DS-0321 FFT 分析功能软件

DS-0371 单通道信号输出模块

ORF格式文件电压输出的操作步骤

株式会社 小野测器

ΟΝΟ Ο ΚΚΙ

DS-0321 FFT 分析功能软件 DS-0371 单通道信号输出模块 ORF格式文件电压输出的操作步骤

本文就用**DS-0350**数据记录(采集)功能软件所产生的ORF格式文件转换成电压输出的操作步骤进行 说明。

■ 操作步骤

- (1) 点击工具栏中的停止键 [50],停止测试。
- (2) 在配置 [Configuration] 窗内,依次点击项目 [Input/Output Setting] ⇒ [Sig Output Setting]
 ⇒ [Open] 等进行设置。

J File(E) Measurement Control(C) Er	I launt/convertigence() Anal	sur(A) Data Disc Seman(D) Mode(30 Sear(A) Mission(M) Optiona(D) Help(D)	
AVG STAT	STOP, EC THIG	SCHED SLOPE SIG OUT	B B 11000 1000
ropency Rarez 20Hz 😒 S	sing Candition Internal 🛒 An	nagre Hodo Power Sun 🐲 Avenue re Court 10	
Typen Moon OneShot M 10	101 101 101 101 101 101 101 101 101 101	Parme Stredition Could a President Title 10	
	1	B- Current Current 3D Schedule Schedule-3D CH1 Tim	e Paal
The		CHI TON BOA	
Manay Control			
Standard County of County	Onen 1		
Orniza Combinistion Serting	Open	05	
+ Freq Flange Setting	0.sb		and the second second second
IF leput Setting	Open	> > > > > > > > > > > > > > > > > > >	
It Sampling Condition Setting 2	derval		
P Rolation Spot Setting	and the state of t	-051	
Uni/Cal Setting	Open		
Window Function Setting	Open		
* Time-anio Preprocessing Sering	Open	in the second seco	- la la
P Averaging Setting	time for	e and and must see east	
R Six Dated Setting	3	as fillness y a 1959	
malyze celling			
Data Dop Setting		DC Tive Ree	
Mode			
Ven			
Cetter			
P Printp			
		-01	
		8 0.004 801, 0.016 100 9.005	
		28 KYRING V TRUETINY	
			1000

(3) 在对话窗 [Sig Output Setting] 内的输出信号模式项 [Signal Output Mode],选择时域记录信号输出 [Timerecord Signalout]。

Wavefo	Wave Signalout Wave Signalout	nalout	
0.14	Timerecord Signal	out	
CHI	Signal Output ON/O	FF Add	tion Function ON/OFF
	Output Mode	Continuous	Exe
	Signal Type	SIN	· · · · · · · · · · · · · · · · · · ·
	Sine Wave Frequency	1000	
	Amplitude	1	
	DC Offset	0	
	Unit	V	~
	🔲 Pink Filter	Output Impe	idance 0Ω 💌
	Burst Setting		Taper Setting
	Cycle 1		Taper
	Time Interval	S	Rising s
	Output Time	S	Fallings

ΟΝΟ ΣΟΚΚΙ

(4) 在 [Time Record Sig Output] 设置画面出现后,点击下列图示对话窗图标 [___],打开文件夹 选择所欲转换成电压信号的ORF格式的文件,然后点击 [Open] 键打开文件。

			-		Û	点击对话窗的
nal Output Mode Timer	ecord Signalout	~			~	
ime Record Sig Outpu	t			1	1	
Select Record Data					1	
File			-6	ล		
Memory Transfer Ran Record No.	nge 0 0	~ 0				
Record CH	Amplit Amplitude	tude Mode Ampl	litude [V] 0.001		/	
				1 17		
		COULT		.0	1	TTT -
Repetitive Outpu		Offline		2	0000	
Repetitive Outpu	3	Offline 201112test_0006.orf 201110test_0005.orf		~	0000	
] Repetitive Outpu] Synchronize with	Recent file list	Offline 201112test_0006.orf 201110test_0005.orf 201110test_0004.orf 201110test_0004.orf 201110test_0003.orf		v	00001	D +
] Repetitive Outpu] Synchronize with	Recent file list	Offline Offline 201112test_0006.orf 201110test_0005.orf 201110test_0004.orf 201110test_0003.orf 201110test_0002.orf 201110test_0002.orf 201110test_0002.orf 201110test_0002.orf			0000	
Repetitive Outpu	Recent file list	Offline 201112test_0006.orf 201110test_0005.orf 201110test_0004.orf 201110test_0003.orf 201110test_0002.orf 201110test_0002.orf 201110test_0001.orf 201110test_0001.o	2 :	▲择所需	●●● □	〕 • 文件
☐ Repetitive Outpu] Synchronize with	Recent file list	Offline 201112test_0006.orf 201110test_0005.orf 201110test_0003.orf 201110test_0003.orf 201110test_0002.orf 201110test_0002.orf RecFile_0001.orf RecFile_0001.orf RecFile_0002.orf RecFile_0002.orf	2 :	▲择所需] ○ ♂ ▷ [言转换的]	<u>□</u> • 文件
Repetitive Outpu	Recent file list	Offline 201112test_0006.orf 201110test_0005.orf 201110test_0003.orf 201110test_0003.orf 201110test_0003.orf 201110test_0002.orf RecFile_0001.orf RecFile_0001.orf RecFile_0000.orf RecFile_0000.orf	2:	▲ 掛所需] ひまさ(<u>□</u> • 文件
Repetitive Outpu	Recent file list Desktop My Document	Offline 201112test_0006.orf 201110test_0005.orf 201110test_0003.orf 201110test_0003.orf 201110test_00003.orf 201110test_00003.orf 201110test_00003.orf @ RecFile_00001.orf @ RecFile_00001.orf @ RecFile_00001.orf	②:)	▲ 选择所需	000	<u>→</u> 文件
Repetitive Outpu	Recent file list Desitop My Document	Offline 201112test_0006.orf 201110test_0005.orf 201110test_0003.orf 201110test_0003.orf 201110test_0002.orf 201110test_0001.orf RecFile_0001.orf RecFile_0001.orf RecFile_0001.orf RecFile_0001.orf RecFile_0001.orf	2:	▲择所需	「「「「」」では、「「」」では、「」」、」、「」、」、」、」、」、」、」、」、、」、」、	<u></u> → 文件
Repetitive Outpu	Recent file list Desitop My Document	Offline 201112test_0006.orf 201110test_0005.orf 201110test_0003.orf 201110test_0003.orf 201110test_0003.orf 201110test_0002.orf 201110test_0002.orf RecFile_0001.orf RecFile_0003.orf RecFile_0003.orf RecFile_0003.orf	2:	▲择所需	「「「「」」では、「「」」では、「」」、」、「」、」、」、」、」、」、」、」、」、、」、、」、、、」、、、、、、	<u>□</u> • 文件
Repetitive Outpu	Recent file list Desitop My Document Wy Computer My Network	Offline 201112test_0006.orf 201110test_0005.orf 201110test_0003.orf 201110test_0003.orf 201110test_0001.orf 201110test_0001.orf RecFile_0001.orf	2:	▲择所需	言转换的∶	文件 Open

(5) 若要确认所需转换的ORF格式文件,可点击浏览图标 [1966] 打开文件浏览器观察所选文件的波形。

Sig Output Setting	3
Signal Output Mode Timerecord Signalout 💌	③ 打开浏览器观察所需转换文件的波形
Time Record Sig Output	
Select Record Data File	101
C:+Documento and Settings+All Usero+Documento+Onocokki DS- 3000+DS-0320+Offline+201110test_0001.orf	
Memory Transfer Range 0 ~ 256000 Record No. 1	
Record CH Amplitude Mode Amplitude [V]	
CH1 CH 1 💌 Amplitude at Recording 💌 0.001 🛄	
2011110test 0001 art (art) [1/1 (0 00002s / Line)] Stor	2 Time-4 99998s - FileView
Renetitive O Eile Display range X-Axis Select Qursor View Help	
□ Synchronize 😹 🛏 🛏 🔍 🗉 💌	
Record.1	
Rec.1 [CH1] Search: X:	0.0s Y: −188.541mV 💽 🕨
447.21mV Adida, Alt A Asst. Assa in a part of a	A + M. A. + A + A + MA A + A + A + A + A + A + A
	<u>Paranda Panana ana ang sang sana ana panana da kanana</u>
-447.21mV	
< A	I Data > 4.99998s
Analysis Range: 0.0s to 5s	REV:0.0 r/min

ΟΝΟ (ΟΚΚΙ

〈注意〉	
1. 当初次打开ORF格式文件时,要注意波形下面是否有全部数据 [All Data] 的标注。若没	有,就得
点击菜单栏内的文件 [File] 项,选择其中的予览项 [Preview File] 以求观察到整个信号	的波形。
201110test 0001 orf < orf> [1/1 00.00002s / Line)] Store Time-4.99998s - FileView File Display rance & Axis Select Qursor View Help Record.1 Rec.1 [CH1] Search: X: 0.0s Y: -188.541mV Y: -188.541mV Art7.21mV Analysis Range: 0.0s to 5s REV:0.0 r/min REV:0.0 r/min Y: -188.541mV	下图显
示当记录序号 [Record. 2] 号文件被打开时的波形。	
201110test_0001_orf <.orf> [1/1 (0.00002s / Line)] Store Time-4.99998s - FileView Eile Display range & Axis Select Qursor View Help	
Record.2 Kec.z torni Search: X: 0.0s Y: -94.535mV	
447.21mV ov MMM/MMM/MM/MM/MM/MM/MM/MM/MM/MM/MM/M/M/M	
< All Data > 4.99998s	
Analysis Range: 0.0s to 5s REV:0.0 r/min	

- (6) 在信号输出 [Time Record Sig Output] 设置窗内,浏览器设置的参数也列在其中。
 - [内存转换范围] (内存单元地址号) / Memory Transfer Range
 - 记录序号 / Record No.

ignal Outp	ut Mode Timerecord	Signalout 🛛 💌	
Time Red	cord Sig Output		
Select File	Record Data		
c:¥doc ¥ds=03	uments and setting 320¥offline¥201110	s¥all users¥documents¥onosok test_0001.orf	ki ds-3000 🛄 🚳
Memor Record	y Transfer Range d No.	0 ~ 256000 2	
	Record CH	Amplitude Mode	Amplitude [V]
CH1	CH1 💌	Amplitude at Recording ⊻	0.001 🛄

ΟΝΟ ΣΟΚΚΙ

(7) [Time Record Sig Output] 设置窗的 [Amplitude Mode] 栏,若 [A/D Data Full-Scale Amplitude] 选择为振幅模式时,在振幅 [Amplitude] 栏内直接键入所对应的输出电压值。

Signal Output Mode Timerecord Signalout ♥ Time Record Sig Output Select Record Data File Stdocuments and settings¥all users¥documents¥onosokki ds-3000 (@ Record No. 2 Record No. 2 Record No. 2 Record CH Amplitude Mode Amplitude [V] CH1 CH1 ♥ Amplitude at Recording ♥ 0.001 Amplitude at Recording A/O Data Full=Scale Amplitude @ Repetitive Output @ Synchronize with Start Data Transfer	6 output octim	b		
Time Record Sig Output Select Record Data File C*documents and settings¥all users¥documents¥onosokki ds-3000 #ds-0302\#offine¥201110test_0001.orf Memory Transfer Range Record No. 2 Record No. 2 Record CH Amplitude Mode Amplitude [V] CH1 CH1 Amplitude at Recording 0.001 Amplitude at Recording A/O Bata Full=Scale Amplitude	Signal Output Mode	Timereco	ord Signalout 🛛 🐱	
Select Record Data File C:Vdocuments and settings¥all users¥documents¥onosokki ds-3000 Vdc-3020¥offine¥201110test_0001.orf Memory Transfer Range 0 ~ 256000 Record No. 2 Record CH Amplitude Mode Amplitude at Recording A/D Data Full-Scale Amplitude Y Repetitive Output Y Synchronize with Start	Time Record Sig	Output		
C Kdocumente and settings¥all usere¥documents¥onosokki ds-3000 ¥ds-0320¥offine¥201110test_0001.orf Memory Transfer Range 0 ~ 256000 Record No. 2 Record CH Amplitude Mode Amplitude [V] OH1 CH1 ≪ Amplitude at Recording ≪ 0.001 Amplitude at Recording ≪ 0.001 Amplitude at Recording A/O Data Full-Scale Amplitude ✓ Repetitive Output ✓ Synchronize with Start	Select Record File	Data		
Memory Transfer Range 0 ~ 256000 Record No. 2 Record CH Amplitude Mode Amplitude [V] CH1 CH1 Amplitude at Recording 0.001 Amplitude at Recording 0.001 Amplitude at Recording 0.001 Provide the second of the se	c:¥documents ¥ds∼0320¥offli	and settin ine¥20111	ngs¥all users¥documents¥onosok IOtest_DDD1.orf	ki ds-3000 🛄 🎑
Record CH Amplitude Mode Amplitude [V] CH1 CH1 Amplitude at Recording 0.001 Amplitude at Recording Amplitude at Recording 0.001 AvD Data Full-Scale Amplitude Amplitude	Memory Trans Record No.	fer Range	0 ~ 256000 2	
CH1 CH1 ✓ Amplitude at Recording ✓ 0.001 Amplitude at Recording A/D Data Full=Scale Amplitude ✓ Repetitive Output ✓ Synchronize with Start	Reco	rd CH	Amplitude Mode	Amplitude [V]
✓ Repetitive Output. ✓ Synchronize with Start Data Transfer	СНІ	сн1 💌	Amplitude at Recording Amplitude at Recording A/D Data Full-Scale Amplitude	0.001
	 ✓ Repetitive Or ✓ Synchronize 	utput with Star	ţ	Data Transfer

(8) 点击数据转换键 [Data Transfer],所指定的ORF格式文件就会被DS-3000本机所读取。数据读取 完毕后在画面上会自动显示数据传送完毕"Data loading has been completed"的信息。

	ut Mode Ti	merecord Si	gnalout 🛛 😽			
Time Rec	ord Sig Ou	tput				
Select File	Record Da	ta				
c:¥doc ¥ds≁03	uments and 20¥offline¥	settings¥a 201110tes	ill users¥docu t_0001.orf	iments¥onosol	ki ds-3000	
Memor Record	y Transfer INo.	Range 0		~ 256000		
	Record C	н	Amplitude	Mode	Amplitude	
CH1	СН	1 🗸	Amplitude at I	Recording 😒		0.001 🛄
	titive Outpu	ut			_	

〈注意〉

1. 读取数据后,若要改变设定条件必须从步骤(4)开始重新进行设置。

ΟΝΟ ΟΚΚΙ

(9) 在 [Time Record Sig Output] 窗的下部,有两个选项。点击 [Synchronize with Start] 意味着电压输出与开始键 [start] 同步,一按了这个键,ORF格式文件就转换成电压并输出。 若点击 [Repetitive Output],输出电压就会周而复始不停地进行,直到停止键 [start] 被按下为止。 若两个选项都不点击时,ORF格式的文件仅转换一次,然后就一直输出 0V 电压,直到本软件工具栏上的信号输出键 [start] 被按下为止。

File c:¥docu ¥ds=032	ments and setting	s¥all users¥documents¥onosoki test 0001 orf	ki ds-3000 🛄 🦓
Memory Record	Transfer Range No.	0 ~ 256000 2	
	Record CH	Amplitude Mode	Amplitude [V]
CH1	СН1 💌	Amplitude at Recording 😒	0.001 [
Repet	itive Output		

下图为用电缆连接DS本机的 Signal Out 输出端至通道 CH 1的输入端,所观察到输出信号的波形。



ΟΝΟ ΣΟΚΚΙ

- (10)关于输出信号的的范围设定,可从步骤(5)开始,打开文件浏览器,在文件浏览器的波形窗内, 边关察边拖动光标来指定欲输出信号的长度范围,然后点击数据转换 [Data Transfer] 键。
 - ① 拖动光标设定长度范围。所指定范围的波形将蒙上一层青色的半透明色彩以示区分(参阅下图)。

ile <u>D</u> isplay range <u>X</u> -Axis <u>S</u> ele	act <u>C</u> ursor <u>V</u> iew <u>H</u> elp			
ecord.2 🔹				
Rec.2 [CH1]	Seath	r: 1.992 54	s to 2.579707s (586.972656m	ns) 🔺 🕨
447.21mV	All A a brat al	المراه المد	A	tra. J. Make
		WWW WY		AVAN AT W
147.01-11				
147.21mV			3	4.00000
447.21mv		< All Data	>	4.99990

① 设置输出信号的长度范围

② 点击范围指定键 []] 以确定数据的长度范围,所摄取的波形变成绿色(参阅下图)。

2011 Otest_0001.orf <.orf>	[1/1 (0.00002s / Line)]	Store Time-4.99998s	- FileView	
<u>File Displatrange X-Axis Selec</u>	t Qursor ⊻iew <u>H</u> elp			
🖻 🛏 🛏 🔍 🖬 💌				
Record.2		1		
Rec.2 [CH1]	Search	: X: .992734s	Y: -38.160mV	4 >
147.21mV	the a heat all	the head of the second	JANE JAA KAN	and all the
A A A A A A A A A A A A A A A A A A A	A Mar Com Charles and Charles		MYWWWWWW	
OV WYWWWWWW	W 77 Y TT . W . W			
447.21mV	a a a a a la			
447.21mV		< All Data >		4.99998s

③ 数据的长度范围一经确定, [Sig Output Setting]窗内 "Memory Transfer Range"内存单元的地 址也被确定。

nai outp	ut Mode Timerecor	d Signalout 🛛 🖌	
ime Rec	ord Sig Output		
Select File	Record Data		
c:¥doc	uments and settin	gs¥all users¥documents¥onosok	ki ds-3000 🛄 🌆
Memor	v Transfer Range	102028 ~ 132081	
Hecoro	No.	9	
100010		<u>-</u>	
	Record CH	Amplitude Mode	Amplitude [V]
CH1	CH1 🔽	Amplitude at Recording 🔽	0.001 🛄
Repe	titive Output hronize with Start		Data Transfer
🗹 Sync			

④ 若要改变所设定的长度范围,重复上述步骤①和②。

ΟΝΟ (ΟΚΚΙ

〈备注〉

● 输出范围设定的存储器地址法

- (1) 依次点击文件浏览器的菜单, [X-axis] ⇒ [Address],可以观察到浏览器波形显示的X轴的单位由时间转变成地址。
- (2) 点击文件浏览器的波形显示图上的任意一点,会瞬即出现光标线,并同时显示点击点的坐标如下 图所示。"Search': X: 27826",暂且记绿下这个光标地址。

Elle Display range B-Avia Select Garser	Zium Budo		
Record.2 ·			
o o tourit	0 L V 0300/	V 150 0.17.1/	4 6
447.21mV	Search: X: 2/826	A A MALLAR A MAL	as de all she d
447.21mV 447.21mV	Man water a start	Notwork Mark	WARN
447.21mV 447.21mV	Search: X: 27820	Not Market	255995

 (3) 依次点击文件浏览器菜单的 [Select] ⇒ [Analysis Range],当 [Analysis Range] 设置窗开启后, 分别键入起点 "Start Address" 和终点 "Stop Address" 的存储单元地址,然后点击 [OK] 键以保 存设置。而 "File size: 0…256000" 标志着ORF文件的长度。

Analysis Range		X		
File Information				
Sound Level				
Range				
 Input Start _Stop Address Input Start Address _Time Range Input Stop Address _Time Range 				
	Calculate			
Start Address	102028]		
Time Range	30053			
Stop Address	132081			
File size: 0	256000			
Record Information				
room		2		
	OK Cancel			

- (4) 文件的长度范围一经确定, [Sig Output Setting]窗内 "Memory Transfer Range"内存单元的地址也被确定了。(参阅步骤(10)-③)。
- (5) 若文件的长度范围选择为全数据,只要在步骤(3)时将起点 "Start Address" 和终点 "Stop Add ress"的存储单元地址设置为 0 和 256000 即可。

完